



नई दिल्ली नगरपालिका परिषद

270

**WATER QUALITY MONITORING UNIT
AMRIT BHAWAN, VINAY MARG, CHANAKYAPURI
QUALITY CONTROL & TECHNICAL AUDIT CELL
NEW DELHI MUNICIPAL COUNCIL
ISO 9001-2015 CERTIFIED**

SAMPLE NOT COLLECTED
BY UNIT STAFF

1. Name & Address of Sender: - *Principal, JAIN Happy Public School,*
2. Date of Receiving/Collection: - *16-11-2024 Sec-2, DIZ Area, Gole Market*
3. Sample No.: - *11818*
4. Sealed Sample (Yes/No):-

**Drinking Water Testing Report
Test - Results**

Sr. No	Location, Date & Time of Sample Collection Site	Colour (Pt-Co Scale)	Taste & Odour	Turbidity (NTU)	pH	Total Hardness (as CaCO ₃) (mg/l)	TDS (mg/l)	Iron (as Fe) (mg/l)	Chloride (as Cl) (mg/l)	Residual Free Chlorine (mg/l)	Coliform Org. MPN / (100-ml)	E. Coli. MPN / (100 ml)
1. 'A'	<i>Drinking Water</i>	5	<i>Agreeable</i>	0.2	7.9	10	18	0.03	06	NIL	NIL	—
2.												
3.												
4.												
5.												
BIS : 10500 2012	Acceptable Limits	05 max.	Agreeable	1 max.	6.5 To 8.5	200 max.	500 max.	0.3 max.	250 max.	0.2 min.	NIL	NIL
	Permissible Limits (in the absence of alternate source.)	15	Agreeable	5	No relaxation	600	2000	No relaxation	1000	1	NIL	NIL

For JAIN HAPPY SCHOOL (RECOGNIZED)
(A Minority Educational Institution)
CBSE Affiliation No. 2730385, School No: 85016,
DOE School No. 2026123

Pr. K. K. K.
Chairman / Manager

Sh. K. K.
Principal

Sh. K. K.
Principal
JAIN HAPPY SCHOOL
(Senior Secondary)
Sector-II, DIZ Area
Gole Market, New Delhi-110004

Remarks:- With respect to above tests, all the above water samples except Sr. No. can/cannot be considered fit for drinking purposes. However minimum residual free chlorine 0.2 mg/l should be done to avoid contamination.

19/11/24
Chemist/Lab Technician

Praveen
19/11/24
Lab. Technician/Asstt.

Note:- 1) water samples will be destroyed after testing unless otherwise specified by party.

NEW DELHI MUNICIPAL COUNCIL
HEALTH DEPARTMENT
PALIKA KENDRA, NEW DELHI

No: D/264/2023 (Health License)

Dated: 02/06/2023

To,


The Principal,
Smt. Shalini Misra,
Jain Happy School (Recognized),
Sector-II, DIZ Area, Gole Market,
New Delhi 110001.

Sub: Health, Water and Sanitation Certificate of Jain Happy School, Gole Market.

Madam,

With Reference to your Application vide E-Receipt No. 1052064 dated 15.05.2023 regarding NOC/Sanitation Certificate for Drinking Water installed to the Jain Happy School (Recognized), Sector-II, DIZ Area, Gole Market, New Delhi 110001.

The premises was inspected on dated 25.05.2023 by the Area Sanitary Inspector (Health) along with SMO and found fit from health, water and sanitation point of view.


(R.P. Sati)
MEDICAL OFFICER OF HEALTH (I/C)
R. P. Sati
Director (Health Licensing)
New Delhi Municipal Council
Palika Kendra, New Delhi